



Phone: 641/673-0411
 Toll-free: 800/825-6020
 Fax: 641/673-5752
 100 1st Ave W
 PO Box 808
 Oskaloosa, IA 52577

Lighting Performance: Track and Field

Horizontal

Light Levels Taken In: Footcandles Lux

Date of Readings : **3/17/2016** By: **Mike Higgins**

Organization Name: **Mt Sac Athletics Complex East**

Organization Contact: _____


Telephone: _____ Email: _____

Facility Address: **1100 N Grand Ave** City, State, Zip: **Walnut, CA 91789**


30' x 30' grid



Field Orientation:
 (Please indicate field orientation in cells around diagram below.)



Pole locations, if applicable, are denoted with an "X":



Horizontal Light Level and Field Survey Results:	
Track average light levels: 57.6	Date lighting system installed: _____
Track uniformity: 6.9:1	Lighting manufacturer: _____
Field average light levels: 51.2	Date of last group relamp: _____
Field uniformity: 7.8:1	Annual hours of operation: _____
(If outdoor) Quantity of poles: _____	Light meter brand: Gossen
Total number luminaires: _____	Model number: Mavolux 5032C
Number luminaires operational: _____	Calibration date: 8/2015
Lamp wattage: _____	
System voltage (if available): _____	